

Use of Micronano Bubble Ozone for Removing Pharmaceutically Active Compounds from Wastewater

Sub-Theme 3

Abstract

The focus was to explore the applicability of the use of Micronano bubbles (MNBs) as a replacement of conventional bubbles in the PACs removal from wastewater. In this study, physico-chemical changes during the MNB ozonation using MNB generator was studied. A recalcitrant water soluble pharmaceutical organic, namely, caffeine that is present in municipal water systems was chosen for study in the lab scale set up

Background

Innovative treatment technologies with higher efficiencies and lower costs are urgently needed for PACs removal at the wastewater treatment plants (WWTPs) before their discharge or reuse. Therefore, the key focus of this research is to maximize the removal of PACs during the disinfection process at the WWTP. Therefore, ozonation with MNB technology (O₃-MNB) is investigated for PACs removal from wastewater.

Objectives

- The main objective of this research was to study the application of MNBs for PACs removal by:
- (1) MNB production using MNB generator in caffeine containing water and study its characteristics
 - (2) Bench scale study to understand removal of caffeine by MNB ozonation, and compare with conventional ozonation



Materials and Methods

The MP-5000 Ozone Generator (A2Z Ozone Inc., USA) was used to feed ozone into NB-200-10 Model microbubble generator (China) to generate O₃-MNB as dissolution in the sealed batch reactor. Microtrac MRB's NANOTRAC Wave II Particle Analyzer (Germany) was used to analyze the ozone-MNB characterization and bubbles distribution at regular intervals. Concentrations of caffeine in the reactor were measured via direct ultra-violet absorption (Hach DR6200 at 272 nm). Other parameters like pH, DO, temperature were also measured at regular intervals during and after the ozonation process.

Experimental Setup



Results



Conclusions

- Nanoparticle analyzer results showed that the microbubble generator produced a good concentration of MNBs
- Initial experiment results showed better removal of caffeine (80%) using MNB ozone. This shows that MNB ozonation at controlled condition would lead to efficient removal of PACs